

INDIAN INSTITUTE OF TECHNOLOGY PATNA

(Store & Purchase Section)

Corrigendum-I

Date : 05.03.2021

Subject: Notice Inviting Tender (NIT) for the supply of **20 KVA Online UPS**.

Tender Reference No.: **IITP/SnP/EPR/1/MA-49/2020-21, Dated: 23.02.2021.**

Tender ID: **2021_IITP_618421_1.**

I. In Technical Specification (Annexure-I):

The specification of **20 KVA Online UPS** to be read as:

20 KVA Online UPS (Qty. – 01) without battery bank.
Sixth (6 th) line of the specification (Minimum VAH (VAH) – 34560) is removed.
Additional specification: UPS should be compatible with existing battery bank (12V/100Ah/SMF x 32 Pcs.)

II. The last date of bid submission is being extended as per following schedule:

Last date and time for submission of quotation to be read as 15.03.2021 (till 03:00pm).

Opening date and time of quotation to be read as 16.03.2021 (03:30pm).

Other terms and conditions remain unchanged.